

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. **01**

Dated: **17.04.2026**

It is certified that an inspection team headed by **Santosh Kumar Bhatti**

(Name of Officers with designation) from **Junior Engineer** PHED

inspected the **The Nyan Bhairav Global School**

(Name & Address of the school) on .....(date of inspection) and on the basis of

Water Test Report (Attached) bearing no. **TC-15867/26/0100000008** dated **17.04.2026**

of **District Water Testing Laboratory** (PHED Lab) certified that

the **The Nyan Bhairav Global School** (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till **One Year**

Signature with Seal: **17/04/25**

Name

Designation

Name & Address of the Office / Department : **PHED**

**17/04/25**  
District Water Testing Lab  
PHED-Siwan

**Brijhasini Yadav**

**Chemist**

To

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Govt. of Bihar  
District Water Testing Laboratory

PHED, Siwan  
**TEST REPORT**

DOC NO : SWN /SAMP/05/00

Name & Address Of the Customer :	ULR NO	TC-15867/26/0/00000008/F
THE GYAN BHAIKAV GLOBAL SCHOOL Ramdhani Campus, Harpur Guthani, Siwan, Bihar	Report No.	SWN/W/26-27/R/08
	Date of Reporting	17.04.2026
	Sample No.	SWN/W/26-27/08
	Sample Description	Drinking Water
	Sample Mark/ Location	
	Sample Submitted in Lab On	16.04.2026
	Sampling Plan & Method	IS 17614 (Part 1): 2021
	Date of Completion of Test	17.04.2026
	Ref No. Date	

**Analysis Result**

Sl. No.	Test Parameter	Test Method	IS 10500:2012Amd. 1 & 2		Result
			Acceptable Limit	Permissible Limit	
1	Colour (HU)	IS 3025 (Part 4) : 2021	5	15	2
2	Odour	IS 3025 (Part 5) : 2022	Agreeable	NR	Agreeable
3	Taste	IS 3025 (Part 8) : 2023	Agreeable	NR	Agreeable
4	pH at 25 °C	IS 3025(Part 11) : 2022	6.5	8.5	7.1
5	Turbidity ( NTU)	IS 3025(Part 10) : 2023	1	5	0.6
6	TDS ( mg/l)	IS 3025(Part 16) : 2023	500	2000	247
7	Total Hardness (mg/l)	IS 3025(Part 21) : 2023	200	600	105.84
8	Calcium ( mg/l)(as ca)	APHA 24th Adition-3500- Ca Method B : 2023	75	200	25.08
9	Magnesium ( mg/l)(asMg)	APHA 24th Adition-3500-Mg Method B : 2023	30	100	10.30
10	Chloride ( mg/l)(as cacO <sub>3</sub> )	IS 3025(Part 32) : 2019	250	1000	18.12
11	Total Alkalinity (mg/l)(as cacO <sub>3</sub> )	IS 3025(Part 23) : 2023	200	600	89.76
12	Iron ( mg/l)	APHA 24th Edition -3500-Fe Method B : 2023	1.00	NR	0.196

**\*\*End Of Report\*\***

Disclaimer:

- The result relates only to the item(s) tested.
- The report shall not be reproduced except in full, without approval of the laboratory.
- The reserved part of water sample(s) shall be retained for 15 days from the date of issue of the report.
- The results apply to the sample as received.

For District Water Testing Laboratory, PHED, Siwan  
Reviewed & Authorized By

*17/04/26*

Name : Mr. Brihaspati Yadav  
(Authorized Signatory)

